



### NOTES:

1. DO NOT EXCEED ALLOWABLE DIRECT TAP ALLOWED BY PIPE MANUFACTURER. OTHERWISE, USE DOUBLE STRAP SERVICE SADDLE FOR 2" AIR RELEASE.
2. CONE SECTION MAY BE SUBSTITUTED FOR FLAT TOP ACCORDING TO DEPTH.



## THE CITY OF LYNCHBURG

### AIR & VACUUM RELEASE VALVE in PRECAST MANHOLE

USE WITH THE CITY OF LYNCHBURG STANDARD SPECIFICATIONS ONLY

SCALE:  
NOT TO SCALE

REVISION DATE:  
10-21-04

DETAIL #  
**26.11**

SHEET #:  
1 OF 1